

## Pennsylvania Urban and Community Forestry

# Questions about Trees and Utilities

### Q Why is the utility company “butchering” our trees?

- Pruning trees along overhead utility lines reduces electrical interruptions, provides safe conditions for the public, and protects power company employees. Most interruptions during storms are caused by trees. One type of service interruption, called a momentary interruption, is annoying to the customer because it lasts just long enough to affect sensitive electronic equipment such as clocks, VCRs, and computers. A second type, called a sustained interruption, results in a complete loss of power. Sustained outages occur mainly during severe weather, and may cause serious damage to electric facilities.
- The utility company hires contractors whose trained tree workers clear vegetation back to distances that are consistent with safe and reliable electric service. Clearances between trees and wires vary according to different voltages of primary and secondary conductors. Also, pruning practices may differ between urban and rural areas. Most utilities use an arboriculturally correct method called directional pruning, instead of topping and shearing. Directional pruning directs subsequent growth away from wires and leaves no stubs. Even a properly pruned tree growing near wires may have a disfigured appearance.

### Q Can’t wires be buried underground, to get them out of our trees?

- In new developments, electrical conductors usually are placed underground. But to relocate existing wires from poles to an underground installation would be prohibitively expensive. Besides the expense to the utility company, property owners would have to dig up their yards and relocate the electrical entrance to each building at a cost of several thousand dollars. Moreover, the trenching would tear up tree roots, which could injure or kill the trees. Future maintenance of underground utilities can be disruptive to established landscape plants, and repairs would result in longer outages.

### Q How can the conflict between trees and wires be resolved?

- The best long-range solution is to replace incompatible trees (those that interfere with wires) with new trees that will not grow into wires. Trees can be replaced all at once, or one at a time as trees become overmature and unhealthy. The choice between sudden or gradual replacement depends on various considerations, including the type of landscape desired in a neighborhood. A formal design with uniformly spaced trees of the same kind and size requires planting all



PHOTO COURTESY OF GEOFF KEMPTER, ASPLUNDH TREE EXPERT CO.

Trees under these wires were topped improperly several years ago. Vigorous regrowth of slender branches from the stubs of thicker branches grew into the wires, requiring pruning for clearance.



PHOTO COURTESY OF GEOFF KEMPTER, ASPLUNDH TREE EXPERT CO.

After directional pruning of the same trees, branches directed away from the wires were retained instead of being removed, as they previously were. Much of the regrowth will now occur on those retained branches, without interfering with the wires. Although the shape of the trees appears unnatural in the winter, they will be more normal in appearance when covered with foliage and will be healthier throughout the year.

trees at the same time. An informal planting design can be implemented over several years, with less disruption in the appearance of the neighborhood.

- The design concept of trees that are compatible with utility lines has been called “the right tree in the right place.” The right tree for planting under utility wires is a species that will not be taller than 20 to 30 feet at maturity (Table 1). Medium-size trees, up to 45 feet at maturity (Table 2), can be planted near utility lines if they are offset at least 15 feet from the nearest wire. Adequate space for root growth

also is an important consideration when deciding tree size and placement. Low-growing trees are most appropriate if the space for roots between the curb and the sidewalk is less than 4 feet wide. If pedestrians and vehicles pass by the planting site, the variety selected should have ascending branches and a single trunk that can be pruned up for clearance.

## Q Can't we have any large trees?

■ Yes, many residential neighborhoods and other locations can and should accommodate properly placed large trees. Utility lines usually are along just one side of a street; large trees can grow on the opposite side if there is ample space for the roots and branches. Other open spaces away from the street also can accommodate large trees, though they should be planted far enough away from buildings. In fact, a diverse mixture of tree sizes and species tends to be healthier, with fewer disease or insect problems. Large trees are recommended where space permits, as they contribute most to cleaner air, moderating temperatures, and reducing storm water runoff.

## Q Who can answer my other questions?

■ Contact your local utility, Penn State Cooperative Extension office, or Pennsylvania District Forestry office.

Produced by Henry D. Gerhold, professor of forest resources, and William F. Elmendorf, instructor of urban and community forestry.

**Table 1. Low-growing trees compatible under utility wires; mature sizes in urban situations.**

COMMON NAME	SCIENTIFIC NAME	MATURE HEIGHT AND WIDTH	
choke cherry, Shubert	<i>Prunus virginiana</i> Shubert	20–30	15–20
crabapple varieties:	<i>Malus</i> varieties:	16–30	8–30
Adams, Centurion, Harvest Gold, Madonna, Prairifire, Prof. Sprenger, Red Barron, Red Jewel, Sentinel, Snowdrift, Spring Snow, Sugar Tyme, Zumi, or Redbud		depends on variety	
dogwood, kousa, and hybrids:	<i>Cornus kousa</i> and varieties:	20–30	20–30
Celestial, Constellation, Julian, Milky Way, Stardust, Steeple, Stellar Pink			
hawthorn varieties:	<i>Crataegus</i> varieties:	15–30	12–35
Crimson Cloud, inermis, Ohio Pioneer, phaenopyrum, Vaughn, Winter King		depends on variety	
Japanese tree lilac varieties:	<i>Syringa reticulata</i> varieties:		
Ivory Silk, Regent, Summer Snow		20–30	15–25
magnolia, Galaxy	<i>Magnolia</i> Galaxy	20–30	10–15
magnolia, Star	<i>Magnolia stellata</i>	10–20	10–15
maple, Amur	<i>Acer ginnala</i>	15–20	15–20
maple, paperbark	<i>Acer griseum</i>	25–35	15–20
maple, Tatarian	<i>Acer tataricum</i>	15–25	15–25
maple, trident	<i>Acer buergeranum</i>	20–30	20–30
serviceberry varieties:	<i>Amelanchier</i> varieties:	20–30	12–20
Autumn Brilliance, Cumulus, Majestic, Princess Diana, Robin Hill, Tradition		depends on variety	

**Table 2. Medium-size trees compatible near utility wires, offset at least 15 feet; mature sizes in urban situations.**

COMMON NAME	SCIENTIFIC NAME	MATURE HEIGHT AND WIDTH	
birch, Heritage	<i>Betula nigra</i> Heritage	40–50	30–40
cherry varieties:	<i>Prunus</i> varieties:	25–40	12–35
Accolade, Kwanzan, Okame, Rosy Cloud, Sargent columnar		depends on variety	
corktree, Amur, varieties:	<i>Phellodendron amurense</i> varieties:	35–45	30–40
Macho, Shademaster			
goldenrain tree	<i>Koelreuteria paniculata</i>	25–40	25–40
honeylocust, Imperial	<i>Gleditsia triacanthos</i> Imperial	30–40	35–45
hophornbeam, American	<i>Ostrya virginiana</i>	30–40	20–30
hornbeam, American	<i>Carpinus caroliniana</i>	20–35	20–35
hornbeam, fastigiata	<i>Carpinus betulus fastigiata</i>	40–50	30–40
horsechestnut, red	<i>Aesculus x carnea</i>	35–50	30–45
magnolia, Merrill	<i>Magnolia</i> Merrill	25–40	25–40
maple, Crimson King	<i>Acer platanoides</i> Crimson King	40–50	35–45
maple, Olmsted	<i>Acer platanoides</i> Olmsted	35–45	20–25
maple, Norwegian Sunset	<i>Acer truncatum</i> Norwegian Sunset	35–45	25–35
maple, Pacific Sunset	<i>Acer truncatum</i> Pacific Sunset	30–40	25–35
maple, Queen Elizabeth	<i>Acer campestre</i> Queen Elizabeth	30–40	25–35
pagoda tree varieties	<i>Sophora japonica</i> varieties:	40–50	25–40
Halka, Regent, Princeton Upright			
pear, callery, varieties	<i>Pyrus calleryana</i> varieties:	35–45	12–35
Aristocrat, Autumn Blaze, Capital, Chanticleer, Cleveland Pride, Cleveland Select, Valiant, Whitehouse		depends on variety	
yellowwood	<i>Cladrastis kentukea</i>	35–50	40–55

This fact sheet was prepared by Penn State with guidance from the Pennsylvania Urban and Community Forestry Council and support from the Pennsylvania DCNR Bureau of Forestry. For more information, contact the Pennsylvania Urban and Community Forestry Program, School of Forest Resources, The Pennsylvania State University, 334 Forest Resources Bldg., University Park, PA 16802; (814) 863-7941.

This publication is available in alternative media on request.

The Pennsylvania State University is committed to the policy that all persons shall have equal access to programs, facilities, admission, and employment without regard to personal characteristics not related to ability, performance, or qualifications as determined by University policy or by state or federal authorities. It is the policy of the University to maintain an academic and work environment free of discrimination, including harassment. The Pennsylvania State University prohibits discrimination and harassment against any person because of age, ancestry, color, disability or handicap, national origin, race, religious creed, sex, sexual orientation, gender identity, or veteran status. Discrimination or harassment against faculty, staff, or students will not be tolerated at The Pennsylvania State University. Direct all inquiries regarding the nondiscrimination policy to the Affirmative Action Director, The Pennsylvania State University, 328 Boucke Building, University Park, PA 16802-5901; Tel 814-865-4700/V, 814-863-1150/TTY.



Pennsylvania Urban and Community Forestry Council